



WALL AS SCHEDULED

JOINT GAP SPACE SHOULD BE NO MORE THAN 1/8". JOINT CAULKING SHOULD BE WATER AND MILDEW RESISTANT. COLOR TO MATCH THE SURFACE

TUBE STEEL CANTILEVER WELDED TO POST

BLOCKING IN WALL FOR ADDED TORSION SUPPORT

TUBE STEEL POST WELDED TO MOUNTING PLATE INSIDE WALL FRAMING

TUBE STEEL MOUNTING PLATE ATTACHED TO FLOOR SLAB WITH EXPANSION BOLTS

24"

LAVATORY—SELF RIMMING (DROP-IN SINK) OR UNDER COUNTER (GLUED-IN) WILL BE SPECIFIED BY DESIGNER

IF COUNTERTOP IS SOLID SURFACE, THEN MACHINED 1/2" SOLID SURFACE TO SERVE AS WATER GUARD — GLUED TO THE EDGE OF THE COUNTER

COUNTERTOP WITH SUBSTRATE AS SCHEDULED

BACK SPLASH & SIDE SPLASH WHERE UNIT IS INSTALLED ADJACENT TO WALL

LAVATORY MOUNTED SOAP DISPENSER (1/ PER LAVATORY)

FLOOR AS SCHEDULED

27" MINIMUM CLEAR

34"

4"

+/-7"

1/2"

GC/AOR TO CONFIRM SIZE OF TUBE STEEL SUPPORTS FOR LOAD RATINGS OF COUNTERTOP (SEE CONSTRUCTION DRAWINGS FOR MORE INFORMATION.)



SINK - RESTROOM SECTION

REV. NO. 001	DWG. NO.
REV. DATE : 1-22-2021	MW-04
DRAWN BY : NBS	SCALE : 1 1/2" = 1'-0"